



S.M.C

Rating factors for variation in thermal resistivity of soil for two or three single-core cables laid direct in the ground.

Nominal Area of Conductor mm ²	Thermal Resistivity of Soil in K.m/W										
	0.7	0.8	0.9	1.0	1.2	1.5	2.0	2.5	3.0	3.5	4.0
50	1.21	1.16	1.11	1.07	1.0	0.91	0.81	0.73	0.68	0.63	0.59
70	1.22	1.16	1.12	1.07	1.0	0.91	0.81	0.73	0.68	0.63	0.59
95	1.22	1.16	1.12	1.07	1.0	0.91	0.81	0.73	0.68	0.63	0.59
120	1.22	1.16	1.12	1.07	1.0	0.91	0.81	0.73	0.68	0.63	0.59
150	1.22	1.16	1.12	1.07	1.0	0.91	0.81	0.73	0.68	0.63	0.59
185	1.22	1.17	1.12	1.07	1.0	0.91	0.81	0.73	0.68	0.62	0.59
240	1.23	1.17	1.12	1.07	1.0	0.91	0.80	0.73	0.68	0.62	0.59
300	1.23	1.17	1.12	1.07	1.0	0.91	0.80	0.73	0.68	0.62	0.59
400	1.23	1.17	1.12	1.07	1.0	0.91	0.80	0.73	0.67	0.62	0.58
500	1.23	1.17	1.12	1.07	1.0	0.91	0.80	0.73	0.67	0.62	0.58
630	1.23	1.17	1.12	1.07	1.0	0.91	0.80	0.73	0.67	0.61	0.58
800	1.23	1.17	1.12	1.07	1.0	0.91	0.80	0.72	0.66	0.61	0.58
1000	1.25	1.18	1.12	1.07	1.0	0.91	0.80	0.72	0.66	0.61	0.58