



# S.M.C

## ***Cables installed in single way ducts***

Group rating factors for multicore core cables in single way ducts,  
horizontal formation (average value)

	Spacing				
	Number of Ducts in Ground	Touching	0.30m	0.45m	0.60m
3.6/6 to 12/20kV Cables	2	0.8	0.91	0.93	0.94
	3	0.8	0.84	0.87	0.89
	4	0.7	0.81	0.84	0.87
	5	0.7	0.77	0.82	0.85
	6	0.6	0.75	0.80	0.84
18/30kV cables	2	0.8	0.89	0.92	0.93
	3	0.7	0.82	0.85	0.87
	4	0.7	0.78	0.82	0.85
	5	0.6	0.75	0.79	0.83
	6	0.6	0.73	0.78	0.82