



S.M.C

Group rating factors single core cables

Group rating factors for single core cables in trefoil.
single way ducts, horizontal formation (average value).

	Spacing				
	Number Of Circuit	Touching	0.45m	0.60m	
3.6/6 to 12/20kV Cables	2	0.85	0.88	0.90	
	3	0.75	0.80	0.83	
	4	0.70	0.76	0.80	
	5	0.67	0.73	0.77	
	6	0.64	0.71	0.76	
18/30kV cables	2	0.85	0.88	0.90	
	3	0.76	0.80	0.83	
	4	0.71	0.76	0.80	
	5	0.67	0.73	0.77	
	6	0.65	0.71	0.76	