



S.M.C

Cables Copper Conductor XLPE Insulated Cables
 SHORT CIRCUIT CURRENT CURVES FOR
 COPPER CONDUCTOR XLPE INSULATED CABLES

$$I_{sc} = 0.14 \frac{A}{\sqrt{t}}$$

I_{sc} - Short Circuit Current in KA
 A - Conductor Area in Sqmm
 t - Short Circuit Time in Sec.

