

B · A · S · E · C

BRITISH APPROVALS SERVICE FOR CABLES

Product Certification Schedule

Schedule No.: 087/001/037
Licensee: SYRIAN MODERN CABLE COMPANY, ADRA, TEL KURDI, DAMASCUS, SYRIA
Factory: SYRIAN MODERN CABLE COMPANY, ADRA, TEL KURDI, DAMASCUS, SYRIA
Specification: BS 5467:1997 + A3:2008 - Specification for 600/1000V and 1900/3300V armoured electric cables having thermosetting insulation.
Type of Cable: Table 8 - Three-core 600/1000V cables with stranded copper conductors
HAR Document: Not applicable
HAR Specification: Not applicable
Range of Approval: 1.5sqmm to 400sqmm nominal cross-sectional area of conductors inclusive. 3-core. Sheath - Type 9. Insulation - GP8.
Origin Thread: Not applicable
Origin Mark: SMC

PERMISSIBLE MARKS



BASEC (yr) 4

YELLOW
ACETATE
THREAD

Please refer to the BASEC Product Certification Requirements

Please note (yr) indicates either the year as a four digit number or manufacturer's code for the year (when required by the standard) and 4 indicates new core colours

Expiry Date: 18/01/2012



Signed for and on behalf of the British Approvals Service for Cables

Chief Executive

Date 22/12/2008



004